




LeRoy-Ostrander Public School
Educational Excellence, For Life



*Predictive
Technologies Inc*
... A Partnership in Reliability



Leroy-Ostrander School District Mechanical Integrity: Steam Piping Thickness Testing

**LeRoy-Ostrander Public Schools
406 W Main ST
LeRoy, MN 55951**

**Gregg Schwartz
Sr. Reliability Engineer
ISO Category: Level III**

**Eric Espe
NDT: Quality Assurance Manager
Level I: IR/VIB/PT/PA
Level II UT/VT/MT/ET**

March 9th, 2017

Non-Destructive Testing

PREDICTIVE ANALYST: _Eric Espe_____ **DATE:** March 9th, 2017

Non-Destructive Testing Procedure



Predictive Technologies
18827 570th Ave
Austin, MN. 55912
(507) 438-6703

Document Title: Predictive Technologies Inc., Non-Destructive Testing Procedure				Page 1 of 1
Document Type: Procedure	Document Number QC-1, VT-1, UT-1, MT-1, PT-1	Initial Date 3/15/2014	Revision 1.0	Effective Date 3/15/2014
Equipment: Olympus EPOCH 600, S#140613801 Transducer: V260-SM, S# 916389		Calibration Information: Certificate # 41E9E22EA38D1EB8, 1/31/2015		Approve Date 3/15/2014

Miscellaneous Information

Action Code Descriptions on Piping Inspection Record

1	Asset Critical – underrated, leaking, welding involved for repair/replacement, possible shutdown required (requires individual work order and/or FCR)
2	Non-welded correction action – painting, thread adjustments, supports, chafing, etc. (bulk work order)
3	Non-operations deficiencies – engineering, inspections, etc.

Key to Information Provided Throughout Report

CUI	Corrosion Under Insulation
CML	Condition Monitoring Location
WPB	Wrought Process Base (Type of Material: Grade, Content)
LLC	Light Local Corrosion
LGC	Light General Corrosion
MLC	Moderate Local Corrosion
MGC	Moderate General Corrosion
AUT	Automated Ultrasonic Testing
MFL	Magnetic Flux Leakage
VTU	Visual Testing Unsatisfactory
HAZ	Heat Affected Zone
ERW	Electric Resistance Weld (85% of Seamless Joint Efficiency)
Ingress	An area that moisture can accumulate

Key to Certifications

ET	Eddy Current
IR	Infrared Analysis
MT	Magnetic Particle Examination
PA	Phased Array
PT	Dye Penetrant
UT	Ultrasonic Thickness Testing
VIB	Vibration Analysis
VT	Visual Inspection Testing

Overall Results Summary

Leroy - Ostrander: Summarized Results										
Section #	Date of Survey	Equipment Tested	Nominal Thickness	Lowest Current Thickness	Lifetime Corrsion Rate Annually	Remaining Half life (yrs)	Next Inspection: API510/570	Next Inspection Ultrasonic	Condition	Comments
1	3/9/2017	(Entrance 4) 1/2" Steam	0.109	0.058	0.011"	2.0	N/A	2018	Alarm	Defiencies Exist: See detailed report.
2	3/9/2017	(Boiler Room) Pump 2 to Gate Valve	0.154	0.101	0.0106"	3.8	N/A	2018	Alert	Deficiencies Exist: See detailed report.
3	3/9/2017	(Boiler Room) Pump 4 to Gate Valve	0.154	0.132	0.0044"	12.6	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
4	3/9/2017	(Boiler Room) 10" Main Header	0.365	0.3	0.013"	9.4	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
5	3/9/2017	(Boiler Room) Pump 2 / Pump 4 Header	0.365	0.358	0.0014"	107.6	N/A	2018	Acceptable	None Noted at Time of Inspection.
6	3/9/2017	(Boiler Room) Pump 2 & 4 Riser to Header	0.216	0.197	0.0038"	22.0	N/A	2018	Acceptable	None Noted at Time of Inspection.
7	3/9/2017	(Boiler Room) 3" Supply to Pumps 2 & 4	0.216	0.185	0.0062"	12.5	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
8	3/9/2017	(East AHU) 2" Steam	0.154	0.129	0.005"	10.8	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
8	3/9/2017	(East AHU) 3" Steam	0.216	0.190	0.0052"	15.2	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
9	3/9/2017	(Little Gym) 1" Steam	0.133	0.126	0.0014"	38.5	N/A	2018	Acceptable	None Noted at Time of Inspection.
9	3/9/2017	(Little Gym) 3" Steam	0.216	0.186	0.006"	13.0	N/A	2018	Acceptable	None Noted at Time of Inspection.
10	3/9/2017	(Media Center) 1" Steam	0.179	0.162	0.0034"	20.4	N/A	2018	Acceptable	None Noted at Time of Inspection.
10	3/9/2017	(Media Center) 3" Steam	0.216	0.183	0.0066"	11.5	N/A	2018	Acceptable	None Noted at Time of Inspection.
10	3/9/2017	(Media Center) 4" Steam	0.237	0.236	0.0002"	507.6	N/A	2018	Acceptable	None Noted at Time of Inspection.
11	3/9/2017	(Classroom 101) 3/4" Steam	0.113	0.107	0.0012"	38.4	N/A	2018	Acceptable	None Noted at Time of Inspection.
12	3/9/2017	(Classroom 102) 3/4" Steam	0.113	0.104	0.0018"	24.7	N/A	2018	Acceptable	Deficiencies Exist: See detailed report.
13	3/9/2017	(Classroom 201) 3/4" Steam	0.113	0.098	0.0030"	13.8	N/A	2018	Acceptable	None Noted at Time of Inspection.
		Note: Refer to the Piping Inspection Records for Analysis. This is used only as a summary and isn't meant to be the final analysis.								

Entrance 4

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander		P&ID No. (First & Last):	Status		A		Inspection Interval (yrs)	5	
Line No.	N/A		N/A	Regulated By:		Owner		X	API	PSM
Description	Entrance Heater		Insulated		0%		Underground			
Location	Entrance 4		Vibration:		Light		Moderate		Heavy	
Service (Oil, Gas, Etc.)	Steam		Sour Service		<input type="checkbox"/>		Sand Producing/High Velocity		<input type="checkbox"/>	
Fabrication Code	B 31.1		Piping Class (1,2,3,4)		4		Injection Point		<input type="checkbox"/>	
Comments			Air to Ground		<input type="checkbox"/>		Corrosion Coupon		<input type="checkbox"/>	
			Over Water		<input type="checkbox"/>		Anodes		<input type="checkbox"/>	
			Inspection Type:		Full		<input type="checkbox"/>		Partial	
			Other (Specify)				UT/VT		<input checked="" type="checkbox"/>	

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 N/A Non-typical fittings/components in service (see comments).
 N/A Condition of insulation: Good Fair Poor
 X Condition of supports/restraints (see comments) X Satisfactory Unsatisfactory
 N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT
 x UT Readings Taken. 100 % UT Taken Inaccessible Insulated Not Required
 NA Other NDE. % Other Type (LFET, PT, MT, Etc.)
 N/A Thickness measurements are less than minimum to meet design pressure requirements
 N/A Engineering evaluation requested (see comments).

Comments: 1. Internal Corrosion Pitting/w threaded components. Nominal Thickness 0.109, Remaining Thickness 0.058

2.
3.
4.
5.
6.
7.
8.
9.
10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Monitor piping with ultrasonic thickness testing. 0.058" remaining, minus 0.057" thread-cut. Pipe could have pitting near 0.001" remaining at threads. Owner/User to decide if piping is replaced due to potential of leaking threaded components.	Ins	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Entrance 4			PAINT/INSULATION	None
DESCRIPTION	Entrance Heater			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Threaded Components w/ Corrosion Pitting

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location 1938 Entrance 4 Description Heater

Inspection Information			
Pipe Size	<u>0.5</u>	D = Outside Diameter	<u>0.8</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.113</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.058</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{0.84}{30} \times 0.4))} = \frac{25.2}{34,024} + 0.014$$

$$t = \text{Required Minimum Thickness} = \underline{0.0147}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

THIS PIPE DOES NOT MEET THE STRUCTURAL MINIMUM THICKNESS FOR CONTINUED SERVICE.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1130 - 0.0580}{5} = \frac{0.0550}{5} = \underline{0.0110 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.0580 - 0.0147}{0.0110} / 2 = \frac{0.0433}{0.0110} \div 2 = 3.9 / 2 = \underline{2.0 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Feb 2019

Comments


Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Entrance 4



Nominal 0.109 Remaining Metal 0.058



Corrosion and Pitting

(Boiler Room) Pump 2 to Gate Valve

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander		P&ID No. (First & Last):	Status	A	Inspection Interval (yrs)	5
Line No.	N/A		N/A	Regulated By:		Owner	X API PSM
Description	Pump 2 to Gate Valve			Insulated	0%	Underground	
Location	Boiler Room			Vibration:	Light <input checked="" type="checkbox"/>	Moderate <input type="checkbox"/>	Heavy <input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:	Full <input type="checkbox"/>	Partial <input type="checkbox"/>	UT/VT <input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):

N/A Non-typical fittings/components in service (see comments).

N/A Condition of insulation: Good

X Condition of supports/restraints (see comments)

N/A Condition of coating (see comments): Good

UT II Tech: Eric Espe

Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed.

x UT Readings Taken. 83 % UT Taken

NA Other NDE. % Other

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. All piping components threaded and acceptable per B31.1, but has potential for leak due to thread cut.

2. Light general external corrosion throughout.

3. Internal corrosion/pitting noted at location 7. Nominal Thickness 0.154, Remaining Thickness 0.101

4. Location 4 (90) forging imperfection, not comparable thickness from similar 90's. Visual inspection shows imperfection.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Monitor piping with ultrasonic thickness testing. 0.101" remaining minus 0.070" thread-cut could potentially have 0.031" remaining metal near threads.	Maint.	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Remove scale. Seal Coat w/ Devco 235 or 236 for Carbon Steel	Maint.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Monitor with Ultrasonic Thickness Testing.	Ins.	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Monitor with Ultrasonic Thickness Testing and or replace.	Maint.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe

Review

Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS (inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	Pump 2 to Gate Valve			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	All piping components threaded
	Light general external corrosion due to areas of ingress/condensation

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description Pump 2 to Gate Valve

Inspection Information			
Pipe Size	<u>2</u>	D = Outside Diameter	<u>2.4</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.154</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.132</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{2.375}{30} \times 0.4))} = \frac{71.25}{34,024} + 0.019$$

$$t = \text{Required Minimum Thickness} = \underline{0.0211}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1540 - 0.1320}{5} = \frac{0.0220}{5} = 0.0044 \text{ Inches Per Year}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1320 - 0.0211}{0.0044} / 2 = \frac{0.1109}{0.0044} \div 2 = 25.2 / 2 = 12.6 \text{ Years Remaining Half Life}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: **Mar 2022**

Comments

Eric Espe

VT/UT II Tech. Signature

10/31/2016

Date

(Boiler Room) Pump 2 to Gate Valve



Forging Imperfection at Location 4



Close Threaded Nipples/Threaded Fittings



Forging Imperfection at Location 4



Light General Corrosion

(Boiler Room) Pump 4 to Gate Valve

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	<u>Leroy-Ostrander</u>	P&ID No. (First & Last):		Status	<u>A</u>	Inspection Interval (yrs)	<u>5</u>
Line No.	<u>N/A</u>		<u>N/A</u>	Regulated By:		Owner	<u>X</u> API <u>PSM</u>
Description	<u>Pump 4 to Gate Vavle</u>			Insulated	<u>0%</u>	Underground	
Location	<u>Boiler Room</u>			Vibration:	<u>Light</u>	<input checked="" type="checkbox"/> Moderate	<input type="checkbox"/> Heavy
Service (Oil, Gas, Etc.)	<u>Steam</u>	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	<u>B 31.1</u>	Piping Class (1,2,3,4)	<u>4</u>	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:		Full	<input type="checkbox"/> Partial <input type="checkbox"/> UT/VT <input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

N/A Condition of insulation: Good Fair Poor

X Condition of supports/restraints (see comments) Satisfactory Unsatisfactory

N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT

x UT Readings Taken. 77 % UT Taken Inaccessible Insulated Not Required

NA Other NDE. % Other Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. Light general external corrosion throughout.

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Remove scale. Seal Coat w/ Devco 235 or 236 for Carbon Steel	Maint.	L-O	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 10/31/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	Pump 4 to Gate Valve			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Internal Corrosion/Pitting Noted
	All piping components threaded
	Light general external corrosion

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description Pump 4 to Gate Valve

Inspection Information			
Pipe Size	<u>2</u>	D = Outside Diameter	<u>2.4</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.154</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.101</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{2.4} \times 0.9) + (\frac{2.375}{30} \times 0.4))} = \frac{71.25}{34,024} + 0.019$$

$$t = \text{Required Minimum Thickness} = \underline{0.0211}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1540 - 0.1010}{5} = \frac{0.0530}{5} = 0.0106 \text{ Inches Per Year}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1010 - 0.0211}{0.0106} / 2 = \frac{0.0799}{0.0106} \div 2 = 7.5 / 2 = 3.8 \text{ Years Remaining Half Life}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Dec 2020

Comments

Eric Espe

VT/UT II Tech. Signature

10/31/2016

Date

(Boiler Room) Pump 4 to Gate Valve



Light General Corrosion



Close Threaded Nipple (CTN)

(Boiler Room) 10" Main Header

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):		Status	A	Inspection Interval (yrs)	5
Line No.	N/A		N/A	Regulated By:		Owner	X API PSM
Description	10 " Boiler Main Header			Insulated	0%	Underground	
Location	Boiler Room			Vibration:	Light <input checked="" type="checkbox"/>	Moderate <input type="checkbox"/>	Heavy <input type="checkbox"/>
				Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
				Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
Comments				Inspection Type:	Full <input type="checkbox"/>	Partial <input type="checkbox"/>	UT/VT <input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: Light (surface rust, no scaling or pitting).
 X Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments): Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good Fair X Poor

X Condition of supports/restraints (see comments) X Satisfactory Unsatisfactory

N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT

x UT Readings Taken. 83 % UT Taken Inaccessible Insulated Not Required

N/A Other NDE. % Other Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. Light general external corrosion throughout and at support hangers. Inspect for corrosion under insulation

2. External pitting/scale on end cap (Loc.1)

3. Leaking valve/flange at location 4.2

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Remove insulation, buff scale. Seal Coat w/ Devoe 235 or 236 for Carbon Steel	Maint.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Remove insulation, buff scale. Seal Coat w/ Devoe 235 or 236 for Carbon Steel	Maint.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Repair leaking valve/flange	Maint.	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe

Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	10" Boiler Main Header			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Light general external corrosion

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description 10" Main Header

Inspection Information			
Pipe Size	<u>10</u>	D = Outside Diameter	<u>10.8</u>
Material	<u>A53 Gr B</u>	S = Allowable Stress Value	<u>16,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.365</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.3</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{16,000}{10.8} \times 0.9) + (\frac{30}{30} \times 0.4))} = \frac{322.5}{27,224} + 0.045$$

$$t = \text{Required Minimum Thickness} = \underline{0.0568}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.3650 - 0.3000}{5} = \frac{0.0650}{5} = \underline{0.0130 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.3000 - 0.0568}{0.0130} / 2 = \frac{0.2432}{0.0130} \div 2 = 18.7 / 2 = \underline{9.4 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

10/31/2016

Date

(Boiler Room) 10" Main Header



Leaking Valve at Loc. 4.1 (CUI)



End Cap Showing Light General w/Pitting



Testing Branch Connections on Header



Support Hangers Under Insulation (LGC)

(Boiler Room) Pump 2 / Pump 4 Header

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	<u>Leroy-Ostrander</u>	P&ID No. (First & Last):		Status	<u>A</u>	Inspection Interval (yrs)	<u>5</u>
Line No.	<u>N/A</u>		<u>N/A</u>	Regulated By:		Owner	<u>X</u> API <u>PSM</u>
Description	<u>P2/P4 Header</u>			Insulated	<u>0%</u>	Underground	
Location	<u>Boiler Room</u>			Vibration:	Light <input checked="" type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input type="checkbox"/>		
Service (Oil, Gas, Etc.)	<u>Steam</u>	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	<u>B 31.1</u>	Piping Class (1,2,3,4)	<u>4</u>	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:	Full <input type="checkbox"/> Partial <input type="checkbox"/> UT/VT <input checked="" type="checkbox"/>		
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good Fair X Poor

X Condition of supports/restraints (see comments) Satisfactory Unsatisfactory

N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT

x UT Readings Taken. 100 % UT Taken Inaccessible Insulated Not Required

N/A Other NDE. % Other Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	P2/P4 Header			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description P2/P4 Header

Inspection Information			
Pipe Size	<u>10</u>	D = Outside Diameter	<u>10.8</u>
Material	<u>A53 Gr B</u>	S = Allowable Stress Value	<u>16,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.365</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.358</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{16,000}{10.8} \times 0.9) + (\frac{30}{30} \times 0.4))} = \frac{322.5}{27,224} + 0.045$$

$$t = \text{Required Minimum Thickness} = \underline{0.0568}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.3650 - 0.3580}{5} = \frac{0.0070}{5} = \underline{0.0014 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.3580 - 0.0568}{0.0014} / 2 = \frac{0.3012}{0.0014} \div 2 = 215.1 / 2 = \underline{107.6 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

(Boiler Room) Pump 2 & 4 Riser

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):		Status	A	Inspection Interval (yrs)	5
Line No.	N/A		N/A	Regulated By:		Owner	X API PSM
Description	P2/P4 Riser to Header			Insulated	0%	Underground	
Location	Boiler Room			Vibration:	Light <input checked="" type="checkbox"/>	Moderate <input type="checkbox"/>	Heavy <input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:	Full <input type="checkbox"/>	Partial <input type="checkbox"/>	UT/VT <input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good Fair X Poor
 X Condition of supports/restraints (see comments) X Satisfactory Unsatisfactory
 N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT
 x UT Readings Taken. 100 % UT Taken Inaccessible Insulated Not Required
 NA Other NDE. % Other Type (LFET, PT, MT, Etc.)
 N/A Thickness measurements are less than minimum to meet design pressure requirements
 N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection
 2.
 3.
 4.
 5.
 6.
 7.
 8.
 9.
 10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	P2/P4 Riser			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):	Status <u>A</u>
Line No.	N/A		Inspection Interval (yrs) <u>5</u>
Description	P2/P4 Riser to Header	Regulated By:	Owner <input checked="" type="checkbox"/> API <input type="checkbox"/> PSM <input type="checkbox"/>
Location	Boiler Room	Insulated	0% <input type="checkbox"/> Underground <input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Vibration:	Light <input checked="" type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input type="checkbox"/>
Fabrication Code	B 31.1	Previous Failure	<input type="checkbox"/> Sand Producing/High Velocity <input type="checkbox"/>
Piping Class (1,2,3,4)	4	Dead Leg	<input type="checkbox"/> Injection Point <input type="checkbox"/>
Comments		Air to Ground	<input type="checkbox"/> Corrosion Coupon <input type="checkbox"/>
		Over Water	<input type="checkbox"/> Anodes <input type="checkbox"/>
		Inspection Type:	Full <input type="checkbox"/> Partial <input type="checkbox"/> UT/VT <input checked="" type="checkbox"/>
		Other (Specify)	

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

☒ External Corrosion: ☒ Light (surface rust, no scaling or pitting).
☐ Moderate (pit depth not greater than C.A./light scale).
☐ Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
☐ Satisfactory ☐ Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

☒ Condition of insulation: ☐ Good ☐ Fair ☒ Poor

☒ Condition of supports/restraints (see comments) ☐ Satisfactory ☐ Unsatisfactory

N/A Condition of coating (see comments): ☐ Good ☐ Fair ☐ Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. ☐ % RT

☒ UT Readings Taken. ☐ 100 % UT Taken ☐ Inaccessible ☐ Insulated ☐ Not Required

NA Other NDE. ☐ % Other ☐ Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

POET Biorefining

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET **1** of **1**

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	P2/P4 Riser			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments: Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description Pump 2 / Pump 4 Riser to Header

Inspection Information			
Pipe Size	<u>3</u>	D = Outside Diameter	<u>3.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.216</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.197</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{3.5}{30} \times 0.4))} = \frac{105}{34,024} + 0.027$$

$$t = \text{Required Minimum Thickness} = \underline{0.0301}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2160 - 0.1970}{5} = \frac{0.0190}{5} = \underline{0.0038 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1970 - 0.0301}{0.0038} / 2 = \frac{0.1669}{0.0038} \div 2 = 43.9 / 2 = \underline{22.0 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

(Boiler Room) Pump 2 & 4 Riser



P2 & P4 Riser to Header

(Boiler Room) 3" Supply to Pumps 2 & 4

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):		Status	A	Inspection Interval (yrs)	5
Line No.	N/A		N/A	Regulated By:		Owner	X API PSM
Description	Supply to Pumps			Insulated	0%	Underground	
Location	Boiler Room			Vibration:	Light <input checked="" type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input type="checkbox"/>		
				Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
				Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
Comments				Inspection Type:	Full <input type="checkbox"/> Partial <input type="checkbox"/> UT/VT <input checked="" type="checkbox"/>		
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good Fair X Poor
 X Condition of supports/restraints (see comments): X Satisfactory Unsatisfactory
 N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT
 x UT Readings Taken. 100 % UT Taken Inaccessible Insulated Not Required
 NA Other NDE. % Other Type (LFET, PT, MT, Etc.)
 N/A Thickness measurements are less than minimum to meet design pressure requirements
 N/A Engineering evaluation requested (see comments).

Comments: 1. Damaged Insulation.

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Repair and or replace damaged insulation.	Mait.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe

Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	Supply to Pumps 2&4			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Boiler Room Description Supply to Pumps 2 & 4

Inspection Information			
Pipe Size	<u>3</u>	D = Outside Diameter	<u>3.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.216</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.185</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{3.5}{30} \times 0.4))} = \frac{105}{34,024} + 0.027$$

$$t = \text{Required Minimum Thickness} = \underline{0.0301}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2160 - 0.1850}{5} = \frac{0.0310}{5} = \underline{0.0062 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1850 - 0.0301}{0.0062} / 2 = \frac{0.1549}{0.0062} \div 2 = 25.0 / 2 = \underline{12.5 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

(Boiler Room) 3" Supply to Pumps 2 & 4



Damaged Insulation

East AHU Steam Line

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):		Status	A	Inspection Interval (yrs)	5
Line No.	N/A		N/A	Regulated By:		Owner	X API PSM
Description	East AHU Steam Line			Insulated	0%	Underground	
Location	Boiler Room			Vibration:	Light <input checked="" type="checkbox"/> Moderate <input type="checkbox"/> Heavy <input type="checkbox"/>		
				Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
				Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
Comments				Inspection Type:	Full <input type="checkbox"/> Partial <input type="checkbox"/> UT/VT <input checked="" type="checkbox"/>		
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good Fair X Poor
 X Condition of supports/restraints (see comments): X Satisfactory Unsatisfactory
 N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT
 x UT Readings Taken. 100 % UT Taken Inaccessible Insulated Not Required
 NA Other NDE. % Other Type (LFET, PT, MT, Etc.)
 N/A Thickness measurements are less than minimum to meet design pressure requirements
 N/A Engineering evaluation requested (see comments).

Comments: 1. Visual Testing Unsatisfactory at location 3. Weld undercut on piping.
 2. Threaded components used in piping circuit.
 3.
 4.
 5.
 6.
 7.
 8.
 9.
 10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Repair weld undercut at location 3.	Maint.	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Monitor with visual inspection.	Maint.	L-O	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	East AHU Steam Line			PAINT/INSULATION	None
DESCRIPTION	Steam Line to East AHU			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Location 3 - VTU, Weld Undercut
	Threaded fittings except at locations 1, 2 and 3

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location East AHU Description East AHU Steam Line

Inspection Information			
Pipe Size	<u>2</u>	D = Outside Diameter	<u>2.4</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.154</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.129</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{2.375}{30} \times 0.4))} = \frac{71.25}{34,024} + 0.019$$

t = Required Minimum Thickness = 0.0211

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1540 - 0.1290}{5} = \frac{0.0250}{5} = \underline{0.0050 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} \div 2 = \frac{0.1290 - 0.0211}{0.0050} \div 2 = \frac{0.1079}{0.0050} \div 2 = 21.6 \div 2 = \underline{10.8 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location East AHU Description East AHU Steam Line

Inspection Information			
Pipe Size	<u>3</u>	D = Outside Diameter	<u>3.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.216</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.19</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{3.5}{30} \times 0.4))} = \frac{105}{34,024} + 0.027$$

t = Required Minimum Thickness = 0.0301

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2160 - 0.1900}{5} = \frac{0.0260}{5} = \underline{0.0052 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} \div 2 = \frac{0.1900 - 0.0301}{0.0052} \div 2 = \frac{0.1599}{0.0052} \div 2 = 30.8 \div 2 = \underline{15.4 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

East AHU Steam Line



VTU – Undercut on pipe Loc. 3



Undercut/Underfill Loc. 3

Little Gym AHU Steam Lines

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):	Status	A	Inspection Interval (yrs)	5			
Line No.	N/A	N/A	Regulated By:	Owner	X	API	PSM		
Description	Steam Lines for AHU		Insulated	0%	Underground				
Location	Little Gym		Vibration:	Light	<input checked="" type="checkbox"/>	Moderate	<input type="checkbox"/>	Heavy	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>		
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>		
Comments			Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>			
			Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>			
			Inspection Type:	Full	<input type="checkbox"/>	Partial	<input type="checkbox"/>	UT/VT	<input checked="" type="checkbox"/>
			Other (Specify)						

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

☒ External Corrosion: ☒ Light (surface rust, no scaling or pitting).
☐ Moderate (pit depth not greater than C.A./light scale).
☐ Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
☐ Satisfactory ☐ Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

☒ Condition of insulation: ☐ Good ☐ Fair ☒ Poor

☒ Condition of supports/restraints (see comments) ☒ Satisfactory ☐ Unsatisfactory

N/A Condition of coating (see comments): ☐ Good ☐ Fair ☐ Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. ☐ % RT

☒ UT Readings Taken. ☐ 100 % UT Taken ☐ Inaccessible ☐ Insulated ☐ Not Required

N/A Other NDE. ☐ % Other ☐ Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Little Gym			PAINT/INSULATION	None
DESCRIPTION	Supply Line to AHU's			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Little Gym Description East AHU Steam Line

Inspection Information			
Pipe Size	<u>1</u>	D = Outside Diameter	<u>1.3</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.133</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.126</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{1.315}{30} \times 0.4))} = \frac{39.45}{34,024} + 0.017$$

$$t = \text{Required Minimum Thickness} = \underline{0.0182}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1330 - 0.1260}{5} = \frac{0.0070}{5} = \underline{0.0014 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1260 - 0.0182}{0.0014} / 2 = \frac{0.1078}{0.0014} \div 2 = 77.0 / 2 = \underline{38.5 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Little Gym Description East AHU Steam Line

Inspection Information			
Pipe Size	<u>3</u>	D = Outside Diameter	<u>3.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.216</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.186</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{3.5}{30} \times 0.4))} = \frac{105}{34,024} + 0.027$$

$$t = \text{Required Minimum Thickness} = \underline{0.0301}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2160 - 0.1860}{5} = \frac{0.0300}{5} = \underline{0.0060 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1860 - 0.0301}{0.0060} / 2 = \frac{0.1559}{0.0060} \div 2 = 26.0 / 2 = \underline{13.0 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Little Gym AHU Steam Lines



Little Gym Testing Location

Media Center

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	<u>Leroy-Ostrander</u>	P&ID No. (First & Last):		Status	<u>A</u>	Inspection Interval (yrs)	<u>5</u>
Line No.	<u>N/A</u>		<u>N/A</u>	Regulated By:		Owner	<u>X</u> API <u>PSM</u>
Description	<u>Media Center Spot-check</u>			Insulated	<u>0%</u>	Underground	
Location	<u>Media Center</u>			Vibration:	<u>Light</u>	<input checked="" type="checkbox"/> Moderate	<input type="checkbox"/> Heavy
Service (Oil, Gas, Etc.)	<u>Steam</u>	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	<u>B 31.1</u>	Piping Class (1,2,3,4)	<u>4</u>	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:	Full <input type="checkbox"/> Partial <input type="checkbox"/>	UT/VT	<input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

X Condition of insulation: Good X Fair Poor
X Condition of supports/restraints (see comments) Satisfactory Unsatisfactory
N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT
x UT Readings Taken. 83 % UT Taken Inaccessible Insulated Not Required
N/A Other NDE. % Other Type (LFET, PT, MT, Etc.)
N/A Thickness measurements are less than minimum to meet design pressure requirements
N/A Engineering evaluation requested (see comments).

Comments: 1. None Noted at time of inspection.
2.
3.
4.
5.
6.
7.
8.
9.
10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Media Center			PAINT/INSULATION	None
DESCRIPTION	Spot Check			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Media Center Description Media Center 1" Spot-check

Inspection Information			
Pipe Size	<u>1</u>	D = Outside Diameter	<u>1.3</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.179</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.162</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{1.315}{30} \times 0.4))} = \frac{39.45}{34,024} + 0.022$$

$$t = \text{Required Minimum Thickness} = \underline{0.0232}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1790 - 0.1620}{5} = \frac{0.0170}{5} = \underline{0.0034 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1620 - 0.0232}{0.0034} / 2 = \frac{0.1388}{0.0034} \div 2 = 40.8 / 2 = \underline{20.4 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe
VT/UT II Tech. Signature

3/9/2017
Date

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Media Center Description Media Center 3" Spot-check

Inspection Information			
Pipe Size	<u>3</u>	D = Outside Diameter	<u>3.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.216</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.183</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{3.5}{30} \times 0.4))} = \frac{105}{34,024} + 0.028$$

$$t = \text{Required Minimum Thickness} = \underline{0.0311}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2160 - 0.1830}{5} = \frac{0.0330}{5} = \underline{0.0066 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} \div 2 = \frac{0.1830 - 0.0311}{0.0066} \div 2 = \frac{0.1519}{0.0066} \div 2 = 23.0 \div 2 = \underline{11.5 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location Media Center Description Media Center 4" Spot-check

Inspection Information			
Pipe Size	<u>4</u>	D = Outside Diameter	<u>4.5</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.237</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.236</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{4.5}{30} \times 0.4))} = \frac{135}{34,024} + 0.029$$

$$t = \text{Required Minimum Thickness} = \underline{0.0330}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.1000}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.2370 - 0.2360}{5} = \frac{0.0010}{5} = \underline{0.0002 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} \div 2 = \frac{0.2360 - 0.0330}{0.0002} \div 2 = \frac{0.2030}{0.0002} \div 2 = \text{#####} \div 2 = \underline{507.6 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Media Center



Media Center Testing Location

Classroom 101

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	<u>Leroy-Ostrander</u>	P&ID No. (First & Last):		Status	<u>A</u>	Inspection Interval (yrs)	<u>5</u>
Line No.	<u>N/A</u>		<u>N/A</u>	Regulated By:		Owner	<u>X</u> API <u>PSM</u>
Description	<u>Classroom Heater</u>			Insulated	<u>0%</u>	Underground	
				Vibration:	<u>Light</u>	<input checked="" type="checkbox"/> Moderate	<input type="checkbox"/> Heavy
Location	<u>Classroom 102</u>			Previous Failure		<input type="checkbox"/> Sand Producing/High Velocity	<input type="checkbox"/>
				Dead Leg		<input type="checkbox"/> Injection Point	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	<u>Steam</u>	Sour Service	<input type="checkbox"/>	Air to Ground		<input type="checkbox"/> Corrosion Coupon	<input type="checkbox"/>
Fabrication Code	<u>B 31.1</u>	Piping Class (1,2,3,4)	<u>4</u>	Over Water		<input type="checkbox"/> Anodes	<input type="checkbox"/>
Comments				Inspection Type:		Full <input type="checkbox"/> Partial <input type="checkbox"/>	UT/VT <input checked="" type="checkbox"/>
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
 Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

N/A Condition of insulation: Good Fair Poor

X Condition of supports/restraints (see comments) Satisfactory Unsatisfactory

N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT

x UT Readings Taken. 60 % UT Taken Inaccessible Insulated Not Required

N/A Other NDE. % Other Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Main 101			PAINT/INSULATION	None
DESCRIPTION	Classroom Heater			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Threaded Components

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location 1938 Class Room 101 Description Classroom Heater

Inspection Information			
Pipe Size	<u>0.75</u>	D = Outside Diameter	<u>1.1</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.113</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.107</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{1.05}{30} \times 0.4))} = \frac{31.5}{34,024} + 0.014$$

$$t = \text{Required Minimum Thickness} = \underline{0.0149}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1130 - 0.1070}{5} = \frac{0.0060}{5} = \underline{0.0012 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1070 - 0.0149}{0.0012} / 2 = \frac{0.0921}{0.0012} \div 2 = 76.7 / 2 = \underline{38.4 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Classroom 101



101 Testing Location

Classroom 102

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	<u>Leroy-Ostrander</u>	P&ID No. (First & Last):		Status	<u>A</u>	Inspection Interval (yrs)	<u>5</u>
Line No.	<u>N/A</u>		<u>N/A</u>	Regulated By:		Owner	<u>X</u> API <u>PSM</u>
Description	<u>Classroom Heater</u>			Insulated	<u>0%</u>	Underground	
Location	<u>Classroom 102</u>			Vibration:	<u>Light</u>	<input checked="" type="checkbox"/> Moderate	<input type="checkbox"/> Heavy
Service (Oil, Gas, Etc.)	<u>Steam</u>	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>
Fabrication Code	<u>B 31.1</u>	Piping Class (1,2,3,4)	<u>4</u>	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>
Comments				Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>
				Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>
				Inspection Type:	Full	<input type="checkbox"/> Partial	<input type="checkbox"/> UT/VT
				Other (Specify)			

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

X External Corrosion: X Light (surface rust, no scaling or pitting).
 Moderate (pit depth not greater than C.A./light scale).
 Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments): Pit Scale
 Satisfactory Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

N/A Condition of insulation: Good Fair Poor

X Condition of supports/restraints (see comments) Satisfactory Unsatisfactory

N/A Condition of coating (see comments): Good Fair Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. % RT

x UT Readings Taken. 75 % UT Taken Inaccessible Insulated Not Required

N/A Other NDE. % Other Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. Leaking steam valve

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1. Repair and or replace leaking valve	Maint.	L-O	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Main 102			PAINT/INSULATION	None
DESCRIPTION	Classroom Heater			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Threaded Components

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location 1938 Class Room 102 Description Classroom Heater

Inspection Information			
Pipe Size	<u>0.75</u>	D = Outside Diameter	<u>1.1</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.113</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.104</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{1.05}{30} \times 0.4))} = \frac{31.5}{34,024} + 0.014$$

$$t = \text{Required Minimum Thickness} = \underline{0.0149}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1130 - 0.1040}{5} = \frac{0.0090}{5} = \underline{0.0018 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.1040 - 0.0149}{0.0018} / 2 = \frac{0.0891}{0.0018} \div 2 = 49.5 / 2 = \underline{24.7 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

Classroom 102



102 Leaking Valve

Classroom 201

Leroy-Ostrander School

PIPING INSPECTION RECORD

Facility	Leroy-Ostrander	P&ID No. (First & Last):	Status	A	Inspection Interval (yrs)	5			
Line No.	N/A	N/A	Regulated By:	Owner	X	API	PSM		
Description	Classroom Heater		Insulated	0%	Underground				
Location	Room 201		Vibration:	Light	<input checked="" type="checkbox"/>	Moderate	<input type="checkbox"/>	Heavy	<input type="checkbox"/>
Service (Oil, Gas, Etc.)	Steam	Sour Service	<input type="checkbox"/>	Previous Failure	<input type="checkbox"/>	Sand Producing/High Velocity	<input type="checkbox"/>		
Fabrication Code	B 31.1	Piping Class (1,2,3,4)	4	Dead Leg	<input type="checkbox"/>	Injection Point	<input type="checkbox"/>		
Comments			Air to Ground	<input type="checkbox"/>	Corrosion Coupon	<input type="checkbox"/>			
			Over Water	<input type="checkbox"/>	Anodes	<input type="checkbox"/>			
			Inspection Type:	Full	<input type="checkbox"/>	Partial	<input type="checkbox"/>	UT/VT	<input checked="" type="checkbox"/>
			Other (Specify)						

To be completed in the field (The following conditions apply to equipment listed above):

N/A No areas of concern noted during physical inspection.

☒ External Corrosion: ☒ Light (surface rust, no scaling or pitting).
☐ Moderate (pit depth not greater than C.A./light scale).
☐ Extreme (pit depth greater than C.A./heavy scale).

N/A Visual Examination of existing welds (see comments):
☐ Satisfactory ☐ Unsatisfactory

N/A Non-typical fittings/components in service (see comments).

N/A Condition of insulation: ☐ Good ☐ Fair ☐ Poor

☒ Condition of supports/restraints (see comments) ☒ Satisfactory ☐ Unsatisfactory

N/A Condition of coating (see comments): ☐ Good ☐ Fair ☐ Poor

UT II Tech: Eric Espe Inspection Date: 3/9/2017

To be completed in the office:

N/A RT Performed. ☐ % RT

☒ UT Readings Taken. ☐ 100 % UT Taken ☐ Inaccessible ☐ Insulated ☐ Not Required

N/A Other NDE. ☐ % Other ☐ Type (LFET, PT, MT, Etc.)

N/A Thickness measurements are less than minimum to meet design pressure requirements

N/A Engineering evaluation requested (see comments).

Comments: 1. None noted at time of inspection

2.

3.

4.

5.

6.

7.

8.

9.

10.

Action Items	Resp. Dept.	Govn. By	Mand	Rec	Action Code		
					1	2	3
1.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Final Review:

Authorized UTII Tech: Eric Espe Review Date: 3/24/2016

PIPING THICKNESS MEASUREMENTS
(inches)

SHEET 1 of 1

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Main 201			PAINT/INSULATION	None
DESCRIPTION	Classroom Heater			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Threaded Components

Signature UTII Tech. *Eric Espe*

Piping Remaining Life Calculations

Minimum Required Thickness, Long Term Corrosion Rate and Remaining Life Calculations

Facility Leroy-Ostrander Equip. # N/A Insp. Date 3/9/2017
Location 1950 Class Room 201 Description Classroom Heater

Inspection Information			
Pipe Size	<u>0.75</u>	D = Outside Diameter	<u>1.1</u>
Material	<u>A106B</u>	S = Allowable Stress Value	<u>20,000</u>
Current Inspection Year	<u>2017</u>	P = Design Pressure	<u>30</u>
Initial or Previous Thickness Reading Year	<u>2012</u>	E = Joint Efficiency (<i>seamless E=1</i>)	<u>0.9</u>
API 570 Inspection Interval	<u>5</u>	W = Weld Strength Reduction Factor (<i>W=1 unless temp. above 800°F</i>)	<u>1.0</u>
Initial Thickness	<u>0.113</u>	Y = Temperature Factor	<u>0.4</u>
Actual Thickness	<u>0.098</u>		

Calculation Information

Minimum Thickness Calculation:

$$t = \frac{PD}{2(SE+PY)} = \frac{30}{2 \times ((\frac{20,000}{20,000} \times 0.9) + (\frac{1.05}{30} \times 0.4))} = \frac{31.5}{34,024} + 0.014$$

$$t = \text{Required Minimum Thickness} = \underline{0.0149}$$

Based on the above calculation, this pipe meets the required minimum thickness for continued service at the current pressure.

$$st = \text{Structural Minimum Thickness} = \underline{0.0900}$$

Structural minimum thickness based on carbon pipe

This pipe meets the required Structural Minimum Thickness for continued service.

Corrosion Rate:

$$\frac{t_{\text{initial}} - t_{\text{actual}}}{\text{years between } t_{\text{initial}} \text{ \& } t_{\text{actual}}} = \frac{0.1130 - 0.0980}{5} = \frac{0.0150}{5} = \underline{0.0030 \text{ Inches Per Year}}$$

Remaining Half Life:

$$\frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{Corrosion Rate}} / 2 = \frac{0.0980 - 0.0149}{0.0030} / 2 = \frac{0.0831}{0.0030} \div 2 = 27.7 / 2 = \underline{13.8 \text{ Years Remaining Half Life}}$$

Based on the above corrosion rate and half life calculation, this pipe is due for inspection: Mar 2022

Comments

Eric Espe

VT/UT II Tech. Signature

3/9/2017

Date

DHW Tank

POET Biorefining

TANK THICKNESS MEASUREMENTS
(inches)

SHEET **1** of **1**

FACILITY	Leroy-Ostrander School	LINE NO.	N/A	INSPECTION DATE	3-9-17
LOCATION	Boiler Room			PAINT/INSULATION	None
DESCRIPTION	Storage Tank - DHW			TECHNICIAN	Eric Espe
REMARKS (Insp. Method, Equip. Type, Serial No., Etc.)	UTT, Olympus 38 DL Plus - S/N 120406903, Panametrics D790 - S/N 902401				

[illegible]

Comments:	Components listed as "N/A" at heights, covered, contain excessive part geometry or otherwise not accessible.
	Damaged Insulation Throughout

Signature UTH Tech. *Eric Espe*

DHW Tank



Damaged Insulation